

CENTRAL POWER RESEARCH INSTITUTE  
(MEMBER OF STL)




CPRI

TEST REPORT

Test Report Number	CPRIBPLSTNB19T0729	Date : 22/7/19
Name & address of the Customer	M/s Khushi Industrial Controls Room No.1, Ganesh Compound, Nandhan Industrial Estate, Marol, Andheri, Mumbai-59	
Name & address of the Manufacturer	M/s Khushi Industrial Controls Room No.1, Ganesh Compound, Nandhan Industrial Estate, Marol, Andheri, Mumbai-59	
Particulars of sample tested	415V, 6300A, L.T. Panel (Non Extendable)	
Condition of sample on Receipt	New	
Type	Indoor	
Designation	PCC LT Panel (Non Extendable)	
Serial number	KIC/TYPE TEST/01	
Date(s) of Test(s)	10 <sup>th</sup> April 2019	
CPRI sample code no.	STNB19S0953	
Particulars of tests conducted	Verification of the short circuit withstand strength	
Test in accordance with Standard/specification	As per clause 8.2.3 of IS: 8623 (Part-1)-1993	
Sampling plan	Not applicable	
Customer's requirement	Nil	
Deviations if any	Nil	
Name of the Witnessing persons		
Customer's representative	Shri Rakesh Kumar	
Other than Customer's representatives	Nil	
Test subcontracted with address of the laboratory	None	
Documents constituting this report (in words)		
Number of sheets	Five	
Number of oscillograms	Two	
Number of graphs	Nil	
Number of photos	One	
Number of Test circuit diagrams	Two	
Number of drawings	Two	

(VIPUL SHARMA)  
TEST ENGINEER



(SUMBUL MUNSHI)  
Joint Director  
Approved by

ULR-TC5181190STBT0729 F  
Discipline : Electrical Testing  
Group : Switchgear & Protective Equipment

Sheet 1 of 5

SWITCHGEAR TESTING & DEVELOPMENT STATION  
GOVINDPURA, BHOPAL-462023, INDIA  
Phone: +91(0)755 2586682 Fax: +91(0)755 2587774